



Douglas County School District
Educational Support Services
Learn today. Lead tomorrow.

John F. Zimmerman
Risk Management

Memorandum

To: Parents & Staff

From: Zach Nannestad, Manager
Environmental Health

Date: April 23, 2009

Subject: Radon Survey and Evaluation

Re: Douglas County High School

To whom it may concern:

The intent of this letter is to inform concerned parents and staff that the radon sampling and evaluation for this site has been completed. A survey took place at all occupied areas required by regulation to include building additions and structural remodels.

The result of the survey and evaluation of this site identifies radon concentrations to be all within the EPA guideline of 4 pCi/L for acceptable radon concentrations. No additional radon sampling is required.

If you would like further information pertaining to the survey and evaluation of radon at this site, please feel free to contact me at 303-387-0027, or at zach.nannestad@dcsdk12.org.

Sincerely,

A handwritten signature in black ink, appearing to read "Zach Nannestad".

Zach Nannestad
Environmental Health Manager
Douglas County School District